

ADDENDUM NO. 01

Volume 4 of 8, **Item No. 1 –Mannar-Mullikulam 220kV Double Circuit Transmission Line of Clause No. 1.2.1 220kV Transmission Line** of Section 6A-Employer's Requirements

The above clause given in Bidding Document advertised on October 9, 2025 is as follows.

“ 220 kV double circuit, three phases, Aluminium Conductor Aluminium Clad Steel Reinforced (ACSR/AS) twin Zebra transmission line with two Optical Fibre Ground Wire (OPGW) shall be constructed from Mullikulam Wind Collector Substation to Mannar grid substation having approximately 28 km route length”

Under this Addendum No. 01 the above clause is amended as follows.

“220 kV double circuit, three phases, Aluminium Conductor Aluminium Clad Steel Reinforced (ACSR/AS) twin Zebra transmission line with two Optical Fibre Ground Wire (OPGW) shall be constructed from Mullikulam Wind Collector Substation to Mannar grid substation having approximately 26 km route length”

Please note that **all other parts of this clause will remain unchanged** subjected to the pre-bid meeting minutes dated October 29, 2025, Reply for Clarifications Set No. 1 dated November 4, 2025, and Reply for Clarifications Set No. 2 dated November 13, 2025.